

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7320-0065:117

Page 1 of 1

**CATEGORY:** Speakers

**LISTEE:** Faraday Inc., 805 S. Maumee St., Tecumseh MI 49286  
Contact: Steven A. Blohm (517) 423-2111

**DESIGN:** Speakers, Models 2600, 2603, 2604, 2605, 2610; and Speaker/Strobe Lights, Models 2608-A, -B, -N, -W; 2606, 2607, 2616, 2617 followed by -A, -B, -C, -N, -W, -D, or -S; and 2618-N, -W. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Speaker: 25 Vrms and 70 Vrms  
Strobes: -A, -N (15 cd), 60 flashes/min  
-B, -W (15/75 cd), 60 flashes/min  
-C, -D (75 cd), 60 flashes/min  
-S (110 cd), 60 flashes/min

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction. Models with suffix -A, -B, -N and -W are for ceiling/wall mount. All other Models are for wall mount only.

**MARKING:** Listee's name or registered trademark "FOS", model number, electrical rating and UL label.

**APPROVAL:** Listed as speakers for use with separately listed compatible fire alarm control units. For indoor use only except Model 2610 speaker (no strobe light) is suitable for outdoor when used with 3014 or 3015 back box.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Rev. 01-22-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 20, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy  
Program Manager